USTEX | FIELD REFERENCE

30-day walkthrough record

Selected spill-prevention and release-detection checks under 40 CFR 280.36. Use the facility's applicable state requirements and inspection procedure. This record does not replace annual checks or required equipment testing. For deliveries more than 30 days apart, the federal spill-equipment check may be performed before each delivery.

Facility: _____ Date: _____

Operator / facility ID: _____

Check	Acceptable / Action needed / N/A	Notes / action taken
Inspect spill prevention equipment for damage.		
Check for liquid or debris; document removal by authorized personnel.		
Check the fill pipe for obstruction and the fill cap for secure fit.		
For monitored double-wall spill equipment, check the interstitial area for leakage.		
Check release-detection equipment for alarms or unusual conditions.		
Review release-detection testing records for currency.		
Document deficiencies, action taken, and items requiring qualified service.		

Outstanding items / responsible contact / follow-up date:

_____

References

40 CFR 280.36 — walkthrough inspections

USTEX technical dispatch: (414) 301-3645 | ustex.org/request